

	90 <sup>th</sup> Percentile	Median
Treated Area (Crooks Ave. and South)	6.8 ppb Lead	3.2 ppb Lead
Untreated Area (North of Crooks Ave.)	22.0 ppb Lead	7.8 ppb Lead

**Fall 2016 - First-Draw Lead Levels at LCR Pool Locations**

